SCBA ID:

Cumru Township Fire Department

6.3C SCBA Inspection Checklist

SCBA HARNESS

Straps(Extended fully check for rips,tears)
High Pressue Hose (connected to cylinder)
Cylinder Pressure (change/refill if less than full)

TURN ON CYLINDER

Check HUD Display for indicator lights
Operate Purge Valve
PASS activation (normal & manual)

CLOSE CYLINDER AND DRAIN SYSTEM

FACE PIECE

Straps(extended fully, check for rips, tears)
Operate Voice Transmitter
Check Rubber Seal and Nosecup for wear, rips
Clean Face Piece if needed

IF ANY PROBLEMS ARE FOUND, TAKE UNIT OOS, REPORT TO AN OFFICER

Inspection Date	Cylinder Pressure	Cylinder Changed	Regulator OK	Facepiece OK	Cleaned	Entire Apparatus OK	Remarks	Inspected By

Inspection Date	Cylinder Pressure	Cylinder Changed	Regulator OK	Facepiece OK	Cleaned	Entire Apparatus OK	Remarks	Inspected By